



CITY AND INDUSTRIAL DEVELOPMENT CORPORATION OF MAHARASHTRA LIMITED

(CIN - U99999 MH 1970 SGC - 014574)

Ref. No. CIDCO/FIRE/HQ/2024/885

Date: 04/7/2024

APPENDIX - VII

FIRE SAFETY CERTIFICATE

Certified that the **TRAVANCORE EDUCATIONAL TRUST (HARMONY SCHOOL)** at Plot No.06, Sec-36, Kharghar, Navi Mumbai 410210 comprised of Ground + 4 Upper Floor owned / occupied by **TRAVANCORE EDUCATIONAL TRUST (HARMONY SCHOOL)** have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on 29/06/2024 in the presence of **Mrs. Beena Menon, Principal & M/s. Beena Fire Engineering Pvt. Ltd., Fire License Agency** and that the building/premises is fit for occupancy up to Class XII with effect from 04/07/2024 for a period of 1 Year in accordance with rule and subject to compliance of specific conditions as appended :-

- 1) In build Fire Fighting System Should be kept in good working condition all the time.
- 2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of January & July) & produce the Form 'B' certificate to this department
- 3) School management shall trained all staff members to operate the Fire Extinguisher.

Issued on 04/07/2024 at Navi Mumbai by

Signature with Seal :

Name : Vijay S. Rane

Designation : Chief Fire Officer

Name & Address of Department / Office: Fire Department CIDCO

To,

Principal,

TRAVANCORE EDUCATIONAL TRUST (HARMONY SCHOOL)

Plot No. 06, Sec-36,

Kharghar, Navi Mumbai 410210

Archanee
PRINCIPAL

HARMONY SCHOOL

PLOT NO. 06, SECTOR-36, KHARGHAR

For **TRAVANCORE EDUCATIONAL TRUST**

Radhakrishna
Authorised Signatory

Regd. Office: Nirmal, 2nd Floor, Nariman Point, Mumbai - 400 021 • Tel.: 022 6650 0900

Head Office: CIDCO Bhavan, CBD Belapur, Navi Mumbai - 400 614 • Tel.: 022 6791 8100

Website: www.cidco.maharashtra.gov.in